

# SERIES 53 – BALL

# CHECK VALVE OPTIONS

## SERIES 53 – BALL CHECK VALVE OPTIONS

### • End Connections

- FL x FL - Flange by Flange ( 2" - 24" )
- NPT x NPT - National Pipe Thread x National Pipe Thread ( 1.5" and 2" )

### • Ball Coating

- NBR ( Standard ), Nitrile, Buna 'N'
- PUR, Polyurethane

### • Seating

- Resilient to Epoxy Coated Iron
- Resilient to Bronze
- Bronze to Bronze

### • Valve Material

- Ductile Iron ( Standard )
- 316 Stainless Steel ( 1.5" and 2" NPT only )

### • Ball Weight

- Sinking ( Standard )
- Floating ( For special installations, contact American AVK )

### • Bolting

- Zinc Plated Steel ( Standard )
- 304 Stainless Steel
- 316 Stainless Steel

### • Coating

- Fusion Bonded Epoxy, 8 mils minimum thickness: to AWWA C550 ( Standard )
- Black Alkyd ( Standard 14" and larger )
- Holiday Free Interior – Fusion Bonded Epoxy only
- Holiday Free Exterior – Fusion Bonded Epoxy only
- Holiday Free Interior & Exterior – Fusion Bonded Epoxy only

• NOTE: These are generally available options for AVK AWWA gate valves. Some options are not available for all valve types and sizes. Contact American AVK for details.

Customer: \_\_\_\_\_

Municipality: \_\_\_\_\_

Engineer: \_\_\_\_\_

Requested By: \_\_\_\_\_

Date: \_\_\_\_\_

Approval Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

SERIES 41 & 53 , CHECK VALVES